



City of Westminster

8200 Westminster Boulevard, Westminster, CA 92683 714.898.3311
www.westminster-ca.gov

November 19, 2012

NOTICE TO ALL PLANHOLDERS

SUBJECT: 2012 WATER IMPROVEMENT PROJECT

At Various Locations

ADDENDUM NO. 1

MARGIE L. RICE
Mayor

TRI TA
Mayor Pro Tem

FRANK G. FRY
Council Member

ANDY QUACH
Council Member

TYLER DIEP
Council Member

EDDIE MANFRO
City Manager

All bidders are to make the following changes or clarifications to the Contract Documents and to acknowledge receipt of this addendum by signing this addendum below and **faxing** the signed copy to **714/895-4499**, and including it with the bid. Any questions regarding this addendum should be addressed to Tuan Pham at 714/548-3456.

This addendum forms a part of the Contract Documents and modifies the original Contract Documents. **The bidder shall also acknowledge receipt of this addendum in the space provided on the bid form.** Failure to comply with this requirement may subject bidder to disqualification. All trades affected shall be fully advised of these changes, additions, or deletions.


1. **Replace** "4-inch PVC Pipe C900" with "4-inch Spool" on Detail No. 22 4-inch Blow-off Assembly, shown on improvement plan sheet 1 of 4. See attachment.
2. **Add** "All water valves within the project limits shall be exposed at the end of the working day." after the first paragraph of Item 5, shown on page ASP-6 in the Specifications.
3. **Add** "The removed asbestos cement pipes shall be bagged and tapped at each end and delivered to the address above" after the first paragraph on page ASP-13 in the Specifications.


Marwan Youssef, Public Works Director/City Engineer

I have received Addendum No. 1 and understand the clarifications listed above.

Name of Company _____ Date _____

Signature _____



22 4" BLOW-OFF ASSEMBLY (NOT TO SCALE)